

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7167-0822:113 Page 1 of 1

CATEGORY: Control Unit (Household)

LISTEE: *Honeywell International Inc., 1985 Douglas Drive. N, Golden Valley, MN 5542
Contact: Bob Hodgson (847) 797-4403 Fax (847) 797-4713

DESIGN: Model 5503. Power-limited output. Refer to listee's data sheet for detailed product description and operational considerations. Basic components:

5503	Control Panel
320/330	Control Station/Zone Expander

INSTALLATION: In accordance with listee's printed installation instructions and applicable codes and ordinances.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as a household control unit for use with separately listed compatible initiating and indicating devices. Fire function must be connected in Zone 2; audible devices must be programmed to pulse. Intended for use with Radionics Models D6000 or D6500 digital alarm receivers (CSFM Listing No. 7167-0801:105).

NOTE: Burglary functions not examined.

FORMERLY: 7165-0822:113

XLf: 7165-0801:105

*Rev. 06-17-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager